

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:03 pm

PWS ID: UTAH27002 **Name:** CENTRAL CULINARY WATER CO
Legal Contact: CENTRAL CULINARY WATER ASSOCIAT
 LONNELL PEBWORTH **Rating:** Approved
Address: 130 S 300 E **Rating Date:** 12/30/1899
 CENTRAL, UT 84722 **Activity Status:** Active
Phone Number: 435-574-0122
City Served (Area):
County: WASHINGTON COUNTY
System Type: Community **Last Inv Update:** 09/21/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 09/16/2009 **Total Dsgn Cap:**
Population: 35 **Surveyor:** MICHAEL S MOSS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	PEBWORTH, LONNELL	PRESIDENT	435-474-0122		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered/Unm	0	27
			27 Total Svc Connections

Storage

Total Storage: 100,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	100,000 GAL	Steel		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	CENTRAL HYPOCHLORINATOR		P	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	3 MI SE OF TOWN SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	CENTRAL CULINARY WELL	Active	WL	8	60 GPM	60 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.